

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1753 / मर- 20 / 41

Dated: 15-7-2026

It is certified that an inspection team headed by Shri Yashvendra(Name of Officers with designation) from Chemist, District Lab Baring(Name of Department/ Office) inspected the K.S. Academy, Swargeshwar Mandir Road, Jhakri
Mauranpur (Jhansi) U.P.(Name & Address of the school) on 04/04/26 (date of inspection) and found thatthe K.S. Academy (Name of school) has safe drinking water facilities

for the students and members of staff of the institution and is maintaining the hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department UP Jal Nigam
(Rural) Jhansi

To

K.S. Academy
Swargeshwar Mandir Road
Jhakri, Mauranpur (Jhansi)
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Test Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)

Babina, Jhansi

MSF-5.10.01



Certificate no. TC- 13415

Report number - C/26-27/04/03

Date - 04.04.2026

Page No. - 25 (6)

Customer Details

Office Name and Address K.S. Academy Swargeshwar Mandir Road Jhakri Mauranipur District- Jhansi

Basic details of sample

District	Jhansi	Block	Mauranipur
Gram Panchayat	-	Village	-
Habitation	-	Location	Swargeshwar Mandir Road Jhakri Mauranipur District- Jhansi
Source	R.O.water	Sample Number	3
Quantity of sample	1 Lit.	Date of sample collection	02.04.2026
Sample receiving date	02.04.2026	Name of sample collector	Ganesh
Name of Sample depositor	Ganesh	Date of Initiation of Test	02.04.2026
Date of Completion of Test	04.04.2026		

Technical Data of Analysis

S. No.	TESTED PARAMETERS	OBSERVED VALUES	SPECIFIED VALUES AS Per BIS 10500:2012		TEST METHOD
			Acceptable Limit	Permissible Limit in the absence of Alternate source	
1	pH	7.81	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022
2	Chloride (mg/l)	18.85	250	1000	IS 3025 (Part 32) : 2019
3	Total Hardness (mg/l)	220.0	200	600	IS 3025 (Part 21) : 2023
4	Calcium as Ca (mg/l)	46.40	75	200	IS 3025 (Part 40) : 2024
5	Total Alkalinity (mg/l)	152.0	200	600	IS 3025 (Part 23) : 2023
6	Magnesium as Mg (mg/l)	25.27	30	100	IS 3025 (Part 46) : 2023
7	Sulphate (mg/l)	14.54	200	400	IS 3025 (Part 24 sec 1) : 2022
8	TDS (mg/l)	212	500	2000	IS 3025 (Part 16) : 2023
9	Iron (mg/l)	0.29	1	1	IS 3025 (Part 53) : 2024
10	Fluoride	0.312	1.0	1.5	IS 3025 (Part 60) : 2025

NOTE:

- 1- This certificate is only applicable for the above tested parameters.
- 2- Parameters above permissible limit are bold.
- 3- This certificate refers only to the particular sample(s) submitted for testing.
- 4- This certificate shall not be reproduce, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 5- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 6- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless other wise specified.

----- End of the Report -----

Issued by

(Yashvendra singh)
Technical Manager